

1U VENT

3U DISTRIBUTION RACK WITH
2 x 20A 1 POLE MAINS MCB
2 x SURGE PROTECTION DEVICE
3 x 63A 2 POLE LOAD MCB (1 SYSTEM OUTPUT &
2 CHARGER OUTPUT)

1U VENT

2U 95A DECOUPLING DIODE RACK WITH
LOAD OUTPUT DIGITAL V/I METER

1U VENT

OPUS C 7U RACK
24VDC, 2.2KW
1 X Mains Switch
1 X Battery MCB
1 X MAINS SWITCH 1 X BATTERY MCB
ALARM TERMINALS
TEMPERATURE COMPENSATED CHARGING
BATTERY LVD, REMOTE CONTROL,
RELAY INPUTS & OUTPUTS
SPACE FOR ADDITIONAL 1.1KW

1U VENT

OPUS C 7U RACK
24VDC, 2.2KW
1 X Mains Switch
1 X Battery MCB
1 X MAINS SWITCH 1 X BATTERY MCB
ALARM TERMINALS
TEMPERATURE COMPENSATED CHARGING
BATTERY LVD, REMOTE CONTROL,
RELAY INPUTS & OUTPUTS
SPACE FOR ADDITIONAL 1.1KW


FLOOR MOUNT 45U 19" CABINET ,
600mm W x 600mm D x 2200mm H (INCLUDING PLINTH)
PERSPEX FRONT DOOR, STEEL REAR DOOR,
PLINTH, 6mm GLAND PLATES TOP & BOTTOM

BATTERY BANK 1
4 x 12V, 150AH FRONT TERMINAL BATTERIES
TO PROVIDE 24VDC 300AH

1U HEAVY DUTY BATTERY SHELF

BATTERY BANK 2
4 x 12V, 150AH FRONT TERMINAL BATTERIES
TO PROVIDE 24VDC 300AH

1U HEAVY DUTY BATTERY SHELF



| | | |
|---|-----------------|--------------------------------|
| TITLE : 45U 24VDC 2.2kW DUAL REDUNDANT CHARGING SYSTEM GA | DRAWN BY: JASON | CAB320 |
| FILE : J:\E2005\Sales_CAB FILES\CAB 320\Drawings\CAB320 GA.SKF | ISSUE: 1 | QUOTATION : D030644 |
| SHEET 1 of 1 | REVISION: 0 | APPROVED SIGN: DATE : 15-03-13 |