


Side View



Front View

Bottom View

3U 125V DC DIST PANEL WITH:
3 x 2P 10A INPUT MCB's WITH AUX
2 x 2P 16A INPUT MCB's WITH AUX

3U 24VDC DIST PANEL WITH:
3 x 2P 25A OUTPUT MCB's WITH AUX
1 x DIGITAL VI METER

3U AC DIST PANEL WITH:
1 x MK-60 AC DIGITAL METER,
2 x 2P 10A INVERTER OUTPUT MCB's
2 x 2P 6A 230VAC OUTPUT MCB's

3U AC DIST PANEL WITH:
1 x MK-60 AC DIGITAL METER,
1 x 2P 6A TRANSFORMER INPUT MCB
4 x 2P 6A 120VAC OUTPUT MCB's

2U TRANSFER SWITCH PANEL WITH:
2 x CHANGE OVER BREAK BEFORE MAKE SWITCHES

3U DC/DC CONVERTER RACK WITH:
1 x 480W 125/24VDC DC/DC CONVERTER
(C654-pr-csi-cf-dr-dd)

3U DC/DC CONVERTER RACK WITH:
1 x 480W 125/24VDC DC/DC CONVERTER
(C654-pr-csi-cf-dr-dd)

3U DC/DC CONVERTER RACK WITH:
1 x 480W 125/24VDC DC/DC CONVERTER
(C654-pr-csi-cf-dr-dd)

6U INVERTER RACK WITH:
2 x 1KVA INVERTERS WITH 125VDC INPUT
AND 230VAC 50HZ OUTPUT (IT3658.5)

TRANSFORMER 700VA 230/120V

1U HEAVY DUTY SHELF


1U VENT

2U COVER PLATE

1U VENT

1U VENT

1U VENT



Equipment Detail View



TITLE : 42U 1.5kW 130/24VDC DC/DC CONVERTER AND 1KV REDUNDANT INVERTER WITH TRANSFER - GA

FILE : J:\IE2005\Sales_CUSTOMER FILES_CAB 475\Drawings\CAB475 GA rev3.SKF

SHEET 1 of 1

ISSUE: 1
REVISION: 3

DRAWN BY:
APPROVED BY:
APPROVED SIGN:

Willem



CAB: CAB475
QUOTATION: DO33976
DATE : 08-10-14